



中国国家强制性产品认证证书

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

证书编号/No.: 2021122307114755

认证委托人名称: SHIN HWA ENGINEERING. CO., LTD.

认证委托人地址: 80B-2L, 242, Cheongneung-daero, Namdong-gu, Incheon, Republic of Korea

生产者名称: SHIN HWA ENGINEERING. CO., LTD.

生产者地址: 80B-2L, 242, Cheongneung-daero, Namdong-gu, Incheon, Republic of Korea

生产企业名称: SHIN HWA ENGINEERING. CO., LTD. (L047182)

生产企业地址: 80B-2L, 242, Cheongneung-daero, Namdong-gu, Incheon, Republic of Korea

认证依据标准: GB 3836.1-2010, GB 3836.2-2010, GB 12476.1-2013, GB 12476.5-2013

产品名称: 智能定位器

系列/型号/规格: SP760 系列; Ex d IIC T5/T6 Gb, Ex tD A21 IP66 T80°C/T90°C; 电气参数见附件

上述产品符合《强制性产品认证实施规则 防爆电气》(CNCA-C23-01: 2019)的要求, 特发此证。

发证日期: 2021年11月09日

有效期至: 2026年11月08日

此证书的有效性以定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 或产品客服电话 400-176-1888 查询。



2021.11.09



方圆标志认证集团

地址: 北京市海淀区增光路33号(100048)

<http://www.cqm.com.cn>

A 0049844



中国国家强制性产品认证证书

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. 2021122307114755

NAME AND ADDRESS OF THE APPLICANT

SHIN HWA ENGINEERING.CO.,LTD.

80B-2L, 242, C heongneung-daero, Namdong-gu, Incheon, Republic of Korea

NAME AND ADDRESS OF THE MANUFACTURER

SHIN HWA ENGINEERING.CO.,LTD.

80B-2L, 242, C heongneung-daero, Namdong-gu, Incheon, Republic of Korea

NAME AND ADDRESS OF THE FACTORY

SHIN HWA ENGINEERING.CO.,LTD.

80B-2L, 242, C heongneung-daero, Namdong-gu, Incheon, Republic of Korea

CERTIFICATION STANDARDS

GB 3836.1-2010,GB 3836.2-2010,GB 12476.1-2013,GB 12476.5-2013

NAME, MODEL AND SPECIFICATION

Smart Positioner

SP760 series; Ex d IIC T5/T6 Gb, Ex tD A21 IP66 T80°C/T90°C; Electrical parameters refer to the attachment

THIS CERTIFICATE IS ISSUED AS VERIFICATION THAT THE PRODUCT(S) MENTIONED ABOVE HAS MET THE REQUIREMENTS OF IMPLEMENTATION RULES FOR CHINA COMPULSORY CERTIFICATION (REF NO. CNCA-C23-01: 2019)

INITIAL DATE: 2021-11-09

DATE OF EXPIRY: :2026-11-08

VALIDITY OF THIS CERTIFICATE IS SUBJECT TO POSITIVE RESULT OF THE REGULAR FOLLOW UP INSPECTION BY THE ISSUING CERTIFICATION BODY UNTIL THE EXPIRY DATE.

THE STATUS AND AUTHENTICITY OF THIS CERTIFICATE MAY BE VERIFIED BY VISITING THE OFFICIAL CNCA WEBSITE: WWW.CNCA.GOV.CN OR BY CONTACTING SERVICE TEL OF CQM: 400-176-1888



Handwritten signature



方圆标志认证集团

ADDRESS: No. 33 Zengguang Road, Haidian District Beijing P.R. China (100048)

<http://www.cqm.com.cn>

A 0049845



中国国家强制性产品认证证书

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

附 录

第 1 页 共 2 页

证书编号: 2021122307114755

主证纸号: A 0049844 A0049845

型号: SP760 系列

型号系列说明:

SP760abcdefgh

a 代表作用类型: S 单作用, D 双作用

b 代表移动类型: L1, L2, R0, R1, R2

c 代表反馈信号: 0, 1

d 代表锁条件: 1, 2

e 代表防爆等级: 0, 1, 2, 3, 4

f 代表空气/导管连接: G,N,M

g 代表限位开关: 0, 1

h 代表选配: 0, H

更多详细信息参考说明手册。

防爆标志: Ex d IIC T5/T6 Gb,

Ex tD A21 IP66 T80°C/T90°C

环境温度: -30°C^{-} +70°C (T6 or T80°C) / -30°C^{-} +80°C (T5 or T90°C)

电气参数: DC (4 $\bar{}$ 20) mA

输入信号: DC (4 $\bar{}$ 20) mA (max. 24 mA)

反馈信号: DC (4 $\bar{}$ 20) mA (max. 24 mA)

反馈选配电源: DC (9 $\bar{}$ 28) V (max. 30 V)

注: 此附录与证书同时使用时有效。



Handwritten signature



方圆标志认证集团

<http://www.cqm.com.cn>

A 0049846



中国国家强制性产品认证证书

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

附 录

第 2 页 共 2 页

证书编号: 2021122307114755

主证纸号: A 0049844 A0049845

Ex 设备的特殊使用条件或 Ex 元件的限定使用条件:

- 1) 应使用屈服强度大于 626N/mm^2 的特殊紧固件;
- 2) 需联系制造商获取关于隔爆接合面的详细数据;
- 3) 警告: 潜在静电电荷危险-见使用说明书 (对于非导电材料外壳表面, 应避免传播型刷型放电);
- 4) 应使用工作温度至少 90°C 的电缆和电缆引入装置。

注: 此附录与证书同时使用时有效。



Handwritten signature



方圆标志认证集团

<http://www.cqm.com.cn>

A 0049847